

# Island County Water Well Information



**WellKey: FAN**

## General Information

Owner Name (log): Bob Fakkema

DOE Tag:

DOE NOI:

DOE ID

Well Address:

Well Parcel: [R23320-144-2020](#)

Served Parcel:

Horiz/Vert Accuracy: Site Plan / DEM

Site Type: Well

SWI Rating: Low Risk



## Construction Information

Construction Date: 10/25/72

Driller Name: Whidbey Well Drillers (Faber)


LS Elevation: 373 ft. MSL

Depth Well: 239 ft.

TD Elevation: 134 ft. MSL

WL Measurements: [2 measurements \(Click to View\)](#)

WL Elevation: 163 ft. MSL



## Water Quality Information

Water Samples: [6 samples \(Click to View\)](#)


Avg/Med/Max Arsenic: 0.005 / 0.005 / 0.005 mg/l

Avg/Med/Max Chloride: 22.30 / 22 / 26.5 mg/l

Avg/Med/Max Hardness: 158.00 / 158 / 180 mg/l

Avg/Med/Max Nitrate: 0.51 / 0.4 / 1 mg/l

Bacteria Samps (distribution): [13 samples \(Click to View\)](#)



## Public Water System Information

Pws Name: Secluded Acres Community Assoc

PwsID: [77175](#)

Approved Connects: 0

Pws Source #: SO# 1

Pws Source Name: InAct 01/17/2002 WELL #1

Note: Underlined items in **bright blue** are hyperlinks to additional information / resources.  
Questions? Contact the [Island County Hydrogeologist](#), or visit the [Hydrogeology Web Page](#).

Report Generated: 12/31/2020

